

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0944:109

Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: Norton, 1902 Airport Rd., Monroe, NC 28110
Contact: *Jeff Trull (704) 283-2101 Fax (704) 283-0789

DESIGN: Models POWER PLUS 6600 and 6700 series. Refer to listee's data sheet for model description, electrical rating and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a door closer. For indoor use only. The unit must be connected to a separately listed compatible fire alarm control panel or detector.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**